## SAFETY INSPECTION FOR MISCELLANEOUS EQUIPMENT Date of Inspection: U.S. Army Engineer District, New Orleans Contractor or Unit Contract No. or Activity Inspected by (Signature) Witness (Signature) PORTABLE ELECTRIC HAND TOOLS Yes No N/A NOTE: Safety and Health Requirements Manual (EM385-1-1) references in parentheses. Is personal protective equipment provided for eyes, hands, etc., and their use enforced? (05.A) 2 Are flexible cords approved for that location? (11.A.03) 3 Are flexible cords in continuous lengths without splices? (11.A.03 (c)) Are portable and semi-portable electrical tools and equipment grounded by multiconductor cord and receptacle? (11.C.01 (b)) 5 Are tools grounded with multi-contact plug and receptacle? (11.C.01 (b)) 6 Are GFCI provided in all circuits using portable electric tools? (11.C.05)(a)(b) 7 Are power hand tools inspected and tested? (13.A.02 (b)) 8 Are tools designed to accommodate guards supplied with them? (13.A.03)(a) 9 When overhead work is being done, are means provided to prevent tools from falling? (13.A.04)10 Are only nonsparking tools used in locations where sources of ignition may cause a fire or explosion? (13.A.06) 11 Safety guards shall be provided for all machines using an abrasive wheel. (13.B.01) 12 Has a ring test been done on abrasive wheels before mounting? (13.B.06) Are circular saws equipped with guards that automatically enclose the blade? (13.C.01)**REMARKS:**

LMN Form 385-26-R JAN 97 Proponent: CELMN-SS